

Standard and Balloon Framing on Concrete Foundations

Strong-Wall High-Strength Wood Shearwall Model No.	Panel Evaluation Height, H_e (lb.) ⁶	Allow Vertical Load, P (lb.) ⁴	2,500 psi Concrete						3,000 psi Concrete					
			Seismic ³			Wind			Seismic ³			Wind		
			Allowable ASD Shear Load, V (lb.)	Drift at Allowable Shear, Δ (in.) ⁷	Anchor Tension at Allowable Shear, T (lb.) ¹¹	Allowable ASD Shear Load, V (lb.)	Drift at Allowable Shear, Δ (in.) ⁷	Anchor Tension at Allowable Shear, T (lb.) ¹¹	Allowable ASD Shear Load, V (lb.)	Drift at Allowable Shear, Δ (in.) ⁷	Anchor Tension at Allowable Shear, T (lb.) ¹¹	Allowable ASD Shear Load, V (lb.)	Drift at Allowable Shear, Δ (in.) ⁷	Anchor Tension at Allowable Shear, T (lb.) ¹¹
WSWH12x7	78	1,000	1,300	0.32	13,295	1,670	0.43	17,075	1,300	0.32	13,295	1,670	0.43	17,075
		4,000	1,300	0.32	13,295	1,670	0.43	17,075	1,300	0.32	13,295	1,670	0.43	17,075
		7,500	1,300	0.32	13,295	1,670	0.43	17,075	1,300	0.32	13,295	1,670	0.43	17,075
WSWH18x7	78	1,000	3,795	0.32	23,680	4,470	0.39	27,890	3,795	0.32	23,680	4,470	0.39	27,890
		4,000	3,795	0.32	23,680	4,365	0.38	27,245	3,795	0.32	23,680	4,470	0.39	27,890
		7,500	3,795	0.32	23,680	4,050	0.36	25,285	3,795	0.32	23,680	4,470	0.39	27,890
WSWH24x7	78	1,000	7,450	0.30	33,210	7,795	0.34	34,755	7,450	0.30	33,210	7,795	0.34	34,755
		4,000	7,450	0.30	33,210	7,565	0.33	33,715	7,450	0.30	33,210	7,795	0.34	34,755
		7,500	7,115	0.28	31,715	7,115	0.31	31,715	7,450	0.30	33,210	7,795	0.34	34,755
WSWH12x8	93.25	1,000	1,030	0.40	12,580	1,325	0.53	16,195	1,030	0.40	12,580	1,325	0.53	16,195
		4,000	1,030	0.40	12,580	1,325	0.53	16,195	1,030	0.40	12,580	1,325	0.53	16,195
		7,500	1,030	0.40	12,580	1,325	0.53	16,195	1,030	0.40	12,580	1,325	0.53	16,195
WSWH18x8	93.25	1,000	3,060	0.39	22,835	3,880	0.52	28,925	3,060	0.39	22,835	3,955	0.53	29,490
		4,000	3,060	0.39	22,835	3,650	0.49	27,245	3,060	0.39	22,835	3,955	0.53	29,490
		7,500	3,060	0.39	22,835	3,390	0.46	25,285	3,060	0.39	22,835	3,955	0.53	29,490
WSWH24x8	93.25	1,000	6,240	0.37	33,240	6,650	0.43	35,430	6,240	0.37	33,240	6,910	0.45	36,815
		4,000	6,240	0.37	33,240	6,330	0.41	33,715	6,240	0.37	33,240	6,910	0.45	36,815
		7,500	5,950	0.35	31,715	5,950	0.38	31,715	6,240	0.37	33,240	6,910	0.45	36,815
WSWH12x9	105.25	1,000	850	0.45	11,750	1,095	0.60	15,145	850	0.45	11,750	1,095	0.60	15,145
		4,000	850	0.45	11,750	1,095	0.60	15,145	850	0.45	11,750	1,095	0.60	15,145
		7,500	850	0.45	11,750	1,095	0.60	15,145	850	0.45	11,750	1,095	0.60	15,145
WSWH18x9	105.25	1,000	2,575	0.45	21,680	3,325	0.60	27,975	2,575	0.45	21,680	3,325	0.60	27,975
		4,000	2,575	0.45	21,680	3,235	0.58	27,245	2,575	0.45	21,680	3,325	0.60	27,975
		7,500	2,575	0.45	21,680	3,005	0.54	25,285	2,575	0.45	21,680	3,325	0.60	27,975
WSWH24x9	105.25	1,000	5,150	0.43	30,975	5,890	0.52	35,430	5,150	0.43	30,975	6,120	0.54	36,815
		4,000	5,150	0.43	30,975	5,605	0.50	33,715	5,150	0.43	30,975	6,120	0.54	36,815
		7,500	5,150	0.43	30,975	5,275	0.47	31,715	5,150	0.43	30,975	6,120	0.54	36,815
WSWH12x10	117.25	1,000	700	0.50	10,750	900	0.67	13,855	700	0.50	10,750	900	0.67	13,855
		4,000	700	0.50	10,750	900	0.67	13,855	700	0.50	10,750	900	0.67	13,855
		7,500	700	0.50	10,750	900	0.67	13,855	700	0.50	10,750	900	0.67	13,855
WSWH18x10	117.25	1,000	2,140	0.50	20,055	2,755	0.67	25,840	2,140	0.50	20,055	2,755	0.67	25,840
		4,000	2,140	0.50	20,055	2,755	0.67	25,840	2,140	0.50	20,055	2,755	0.67	25,840
		7,500	2,140	0.50	20,055	2,695	0.65	25,285	2,140	0.50	20,055	2,755	0.67	25,840
WSWH24x10	117.25	1,000	4,010	0.48	26,860	5,215	0.67	34,935	4,010	0.48	26,860	5,215	0.67	34,935
		4,000	4,010	0.48	26,860	5,030	0.64	33,715	4,010	0.48	26,860	5,215	0.67	34,935
		7,500	4,010	0.48	26,860	4,735	0.61	31,715	4,010	0.48	26,860	5,215	0.67	34,935
WSWH12x11	129.25	1,000	595	0.56	10,055	765	0.73	12,930	595	0.56	10,055	765	0.73	12,930
		4,000	595	0.56	10,055	765	0.73	12,930	595	0.56	10,055	765	0.73	12,930
		7,500	595	0.56	10,055	765	0.73	12,930	595	0.56	10,055	765	0.73	12,930
WSWH18x11	129.25	1,000	1,960	0.55	20,240	2,520	0.73	26,060	1,960	0.55	20,240	2,520	0.73	26,060
		4,000	1,960	0.55	20,240	2,520	0.73	26,060	1,960	0.55	20,240	2,520	0.73	26,060
		7,500	1,960	0.55	20,240	2,445	0.71	25,285	1,960	0.55	20,240	2,520	0.73	26,060
WSWH24x11	129.25	1,000	4,000	0.54	29,550	4,795	0.68	35,430	4,000	0.54	29,550	4,985	0.70	36,815
		4,000	4,000	0.54	29,550	4,565	0.64	33,715	4,000	0.54	29,550	4,985	0.70	36,815
		7,500	4,000	0.54	29,550	4,295	0.60	31,715	4,000	0.54	29,550	4,985	0.70	36,815

See footnotes on p. 15.

Standard and Balloon Framing on Concrete Foundations

(cont.)

Strong-Wall High-Strength Wood Shearwall Model No.	Panel Evaluation Height, H _e (lb.) ⁶	Allow Vertical Load, P (lb.) ⁴	2,500 psi Concrete						3,000 psi Concrete					
			Seismic ³			Wind			Seismic ³			Wind		
			Allowable ASD Shear Load, V (lb.)	Drift at Allowable Shear, Δ (in.) ⁷	Anchor Tension at Allowable Shear, T (lb.) ¹¹	Allowable ASD Shear Load, V (lb.)	Drift at Allowable Shear, Δ (in.) ⁷	Anchor Tension at Allowable Shear, T (lb.) ¹¹	Allowable ASD Shear Load, V (lb.)	Drift at Allowable Shear, Δ (in.) ⁷	Anchor Tension at Allowable Shear, T (lb.) ¹¹	Allowable ASD Shear Load, V (lb.)	Drift at Allowable Shear, Δ (in.) ⁷	Anchor Tension at Allowable Shear, T (lb.) ¹¹
WSWH12x12	144	1,000	505	0.61	9,495	645	0.80	12,150	505	0.61	9,495	645	0.80	12,150
		4,000	505	0.61	9,495	645	0.80	12,150	505	0.61	9,495	645	0.80	12,150
		7,500	505	0.61	9,495	645	0.80	12,150	505	0.61	9,495	645	0.80	12,150
WSWH18x12	144	1,000	1,705	0.61	19,665	2,195	0.80	25,285	1,705	0.61	19,665	2,195	0.80	25,285
		4,000	1,705	0.61	19,665	2,195	0.80	25,285	1,705	0.61	19,665	2,195	0.80	25,285
		7,500	1,705	0.61	19,665	2,195	0.80	25,285	1,705	0.61	19,665	2,195	0.80	25,285
WSWH24x12	144	1,000	3,525	0.60	29,015	4,305	0.75	35,430	3,525	0.60	29,015	4,475	0.78	36,815
		4,000	3,525	0.60	29,015	4,100	0.72	33,715	3,525	0.60	29,015	4,475	0.78	36,815
		7,500	3,525	0.60	29,015	3,855	0.67	31,715	3,525	0.60	29,015	4,475	0.78	36,815
WSWH18x13	156	1,000	1,490	0.66	18,575	1,910	0.87	23,855	1,490	0.66	18,575	1,910	0.87	23,855
		4,000	1,490	0.66	18,575	1,910	0.87	23,855	1,490	0.66	18,575	1,910	0.87	23,855
		7,500	1,490	0.66	18,575	1,910	0.87	23,855	1,490	0.66	18,575	1,910	0.87	23,855
WSWH24x13	156	1,000	3,110	0.65	27,705	3,975	0.86	35,430	3,110	0.65	27,705	4,025	0.87	35,885
		4,000	3,110	0.65	27,705	3,780	0.81	33,715	3,110	0.65	27,705	4,025	0.87	35,885
		7,500	3,110	0.65	27,705	3,560	0.77	31,715	3,110	0.65	27,705	4,025	0.87	35,885
WSWH18x14	168	1,000	1,180	0.72	15,890	1,515	0.93	20,370	1,180	0.72	15,890	1,515	0.93	20,370
		4,000	1,180	0.72	15,890	1,515	0.93	20,370	1,180	0.72	15,890	1,515	0.93	20,370
WSWH24x14	168	1,000	2,620	0.71	25,160	3,365	0.93	32,290	2,620	0.71	25,160	3,365	0.93	32,290
		4,000	2,620	0.71	25,160	3,365	0.93	32,290	2,620	0.71	25,160	3,365	0.93	32,290
WSWH18x16	192	1,000	985	0.82	15,160	1,265	1.07	19,395	985	0.82	15,160	1,265	1.07	19,395
		4,000	985	0.82	15,160	1,265	1.07	19,395	985	0.82	15,160	1,265	1.07	19,395
WSWH24x16	192	1,000	2,130	0.82	23,345	2,735	1.07	29,990	2,130	0.82	23,345	2,735	1.07	29,990
		4,000	2,130	0.82	23,345	2,735	1.07	29,990	2,130	0.82	23,345	2,735	1.07	29,990
WSWH18x18	216	1,000	750	0.93	12,965	960	1.20	16,550	750	0.93	12,965	960	1.20	16,550
		4,000	750	0.93	12,965	960	1.20	16,550	750	0.93	12,965	960	1.20	16,550
WSWH24x18	216	1,000	1,655	0.93	20,400	2,110	1.20	26,060	1,655	0.93	20,400	2,110	1.20	26,060
		4,000	1,655	0.93	20,400	2,110	1.20	26,060	1,655	0.93	20,400	2,110	1.20	26,060
WSWH18x20	240	1,000	605	1.04	11,640	770	1.33	14,825	605	1.04	11,640	770	1.33	14,825
		4,000	605	1.04	11,640	770	1.33	14,825	605	1.04	11,640	770	1.33	14,825
WSWH24x20	240	1,000	1,350	1.04	18,500	1,720	1.33	23,590	1,350	1.04	18,500	1,720	1.33	23,590
		4,000	1,350	1.04	18,500	1,720	1.33	23,590	1,350	1.04	18,500	1,720	1.33	23,590

- Allowable shear loads are applicable to installations on concrete with specified compressive strengths as listed using the ASD basic (IBC Section 1605.3.1) or the alternative basic (IBC Section 1605.3.2) load combinations.
- Load values include evaluation of bearing stresses on concrete foundations and do not require further evaluation by the designer. For installations on masonry foundations, bearing capacity shall be evaluated by the designer.
- Seismic design based on 2018 IBC using R = 6.5. For other codes, use the seismic coefficients corresponding to light-frame bearing walls with wood structural panels or sheet-steel panels.
- Allowable vertical load denotes the total maximum concentric vertical load permitted on the panel acting in combination with the allowable shear loads.
- Allowable shear, drift and anchor tension values may be interpolated for intermediate height or vertical loads. For panels 74½"–78" tall, use the values for a 78"-tall panel.
- To achieve required WSWH panel evaluation height, trim next tallest full-height panel defined in table on p. 13.
- Drifts at lower design shear may be linearly reduced.
- See p. 16 for allowable out-of-plane and axial capacities.
- Angled SDS screws may be omitted from the WSWH-TP top connection for all panels taller than 100"; see p. 16 as reduced allowable out-of-plane loads may apply.
- High-strength anchor bolts are required for anchor tension forces exceeding the allowable load for standard-strength bolts tabulated on pp. 22–23. See pp. 21–29 for WSWH-AB anchor bolt information and anchorage solutions.
- Tabulated anchor tension values assume no resisting vertical load. Anchor tension loads at design shear values and including the effect of vertical load may be determined using the following equation:

$$T = [(V \times H) / B] - P/2$$
, where:
 T = Anchor tension load (lb.)
 V = Design shear load (lb.)
 P = Applied vertical load (lb.)
 H = Panel height (in.)
 B = Moment arm (in.); 7.625" for WSWH12, 12.50" for WSWH18, 17.50" for WSWH24.